





ref. 99064859



PROTECTOR-RED- VALVE-4 ANSI 150

VASTE BLUSMONITOREN MANUEEL




6.4 PRESSURE LOSS

The discharge size of the monitor determines maximum flow. Excessive turbulence will result if maximum flow is exceeded.



4" ANSI 150 Flange dimensions



Inch	D	d	a	c	f	PN
4"	228.6 mm	116.1 mm	190.5 mm	157 mm	19.1 mm	20 bar

Vanassche Firefighting Engineering

Brugsesteenweg 8
 B-8531 Harelbeke
 +32 (0) 56 710 130
 info@vanassche-fire.be
 BE 0415.345.684
 RPR Gent - Afdeling Kortrijk
 vanassche-fire.be

Vanassche Services

Brugsestraat 153
 B-8531 Harelbeke
 +32 (0) 56 738 188
 services@vanassche-fire.be
 BE 0473.397.315
 RPR Gent - Afdeling Kortrijk
 vanassche-fire.be